

STATE OF CALIFORNIA
OFFICE OF THE STATE FIRE MARSHAL
FIRE AND LIFE SAFETY DIVISION
FIRE SAFETY CORRECTION NOTICE
EN-11 (12/08)



FIRE SAFETY CORRECTION NOTICE

FILE NUMBER
01-37-41-0005

PAGE
1

OF

PAGE
1

NAME
VETERANS HOME OF CHULA VISTA

ADDRESS
700 E. NAPLES COURT, CHULA VISTA, 91911

The California Health and Safety Code and the State Fire Marshal's Regulations require the following fire safety deficiencies be corrected:

An annual Fire and Life safety inspection was conducted on the facility listed above on September 2, 2009, while accompanied by Roy Breedlove, Support Service Manager and Gil Gabilan, Acting Chief of Plant Operations.

The following deficiencies were found:

1. Housekeeping/fire hazard room A145. Title 19, 3.19, Title 19, 3.14 (corrected)
-Corrected immediately on 9-2-09
2. Riser blocked by storage shelving in building B. CFC 508.5.4
-Storage shelving removed immediately on 9-2-09
3. Fire extinguisher not tagged located in E400. Title 19, 597
-Crossway Fire was contracted to replace missing tags. Corrected on 9-10-09
4. Compressed gas cylinders not secured located in emergency water storage closet. CFC 3003.7.2
-A rack for the cylinders was provided on 9-3-09 by the hospice care provider

The above deficiencies are to be corrected within 30 days. When all deficiencies have been corrected, sign and return a copy of the certification to 602 E. Huntington Dr. Ste. A Monrovia, CA 91016 or P.O. Box 944246, Sacramento, CA 94244-2460. If you have any questions, please contact the Office of the State Fire Marshal at 626-305-1908.

DATE:

SIGNATURE:

ISSUED BY:

Jena Garcia, DSFM

RECEIVED BY:

Roy Breedlove

DATE:

9-2-09